

1.5 to 15

Above 15

## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor:** Fixed Speed

		MODEL DATA - FOR COMPRES	SED AIR		
1	Manufacturer:	Chicago Pneumatic			_
	Model Number:	CPCg 40 - 150 psig	Date:	9/30/2022	_
2	X Air-cooled	Water-cooled	Type:	Screw	
			# of Stages:	1	
3*	Rated Capacity at Full Load Operating Pressure <sup>a, e</sup>		160.0	acfm <sup>a,e</sup>	
4*	Full Load Operating Pressure <sup>b</sup>		150	psig	
5	Maximum Full Flow Operating Pressure <sup>c</sup>		157	psig <sup>c</sup>	
6	Drive Motor Nominal Rating		40	hp	
7	Drive Motor Nominal Efficiency		92.4	percent	
8	Fan Motor Nominal Rating (if applicable)		1.3	hp	
9	Fan Motor Nominal Efficiency		51.6	percent	_
10*	Total Package Input Power at Zero Flow <sup>e</sup>		7.9	kW <sup>e</sup>	
11		er at Rated Capacity and Full Load	37.00	$kW^d$	
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>		23.13	kW/100 cfm <sup>e</sup>	
13	Isentropic Efficiency		71.53	Percent	
Consult NOTES	<ul> <li>CAGI website for a list of partic:</li> <li>a. Measured at the disch ISO 1217, Annex C; 4</li> <li>b. The operating pressure for this data sheet.</li> <li>c. Maximum pressure att maximum pressure att d. Total package input pressure e. Tolerance is specified</li> </ul>	Performance Verification Program, these items are v ipants in the third party verification program: arge terminal point of the compressor package in accord ACFM is actual cubic feet per minute at inlet conditions. e at which the Capacity (Item 3) and Electrical Consump tainable at full flow, usually the unload pressure setting I ainable before capacity control begins. May require add ower at other than reported operating points will vary wit in ISO 1217, Annex C, as shown in table below:	<u>www.cagi.org</u> lance with otion (Item 11) were measured for load/no load control or the litional power. ith control strategy.	4	
ssed Air & Gas Institut	NOTE: The terms "power" and "energy" are synonymous for purposes of this Volume Flow Rate			Specific Energy	No Load / Zero Flow
lambar	m <sup>3</sup> /min	at specified conditions $ft^3 / min$	Volume Flow Rate %	Consumption %	Power %
Aember	$\frac{\text{m}^2 / \text{min}}{\text{Below } 0.5}$	<u>π_/min</u> Below 17.6	% +/- 7	% +/- 8	70
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
	0.0 10 1.5	1,10 10 00	., 0	., ,	+/- 10%

ROT 030.1

Compr

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

+/- 5

+/- 4

+/- 6

+/- 5

53 to 529.7

Above 529.7