

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1 Manufac			OR COMPRESSI	ED AIR			
		Pneumatic					
	Model Number: CPVS 75 55kW			Date:	Date: 09/22/20		
2	Air-cooled W	Type:		Screw			
				# of Stages:		1	
3* Full Loa	ull Load Operating Pressure		181		psig b		
4 Drive M	ve Motor Nominal Rating		75		hp		
5 Drive M	ve Motor Nominal Efficiency		96.0		percent		
6 Fan Mot	Fan Motor Nominal Rating (if applicable)		3.7		hp		
7 Fan Mot	Notor Nominal Efficiency		87.5		percent		
Input	Power (kW)		Capacity (acfm)	l I	Specific Power (kW/100 acfm) ^d		
	62.0		290		21.38		
8*	51.0		239		21.34		
	42.0		186		22.58		
	29.0		119		24.37		
	24.0		93		25.81		
9* Total Pa	tal Package Input Power at Zero Flow c, d		0.0		kW		
10 Isentrop	tropic Efficiency		85.2			%	
11		ote: Graph is only a vis	150 200 Capacity (ACFM) ual representation of the data		0 350	-	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

2/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data