

COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

| | MODEL DATA - F | OR CO | MPRESSED AIR | |
|----|--|----------------------------------|---|---|
| 1 | Manufacturer: Chicago Pneu | ımatic | | |
| 2 | Model Number: CPVS 25 | | Date: | Aug-14 |
| | x Air-cooled Water-co | oled | Туре: | Screw |
| | x Oil-injected Oil-free | | # of Stages: | 1 |
| 3 | Rated Operating Pressure | | 109 | psig ^b |
| 4 | Drive Motor Nominal Rating | | 25 | hp |
| 5 | Drive Motor Nominal Efficiency | | 91 | percent |
| 6 | Fan Motor Nominal Rating (if applicable) | | NA | hp |
| 7 | Fan Motor Nominal Efficiency | | NA | percent |
| 8* | Input Power (kW) | | Capacity (acfm) ^{a,d} | Specific Power (kW/100 acfm) ^d |
| | 23.5 | Max | 109.5 | 21.46 |
| | 20.7 | | 99.5 | 20.80 |
| | 16.3 | | 78.3 | 20.82 |
| | 12.2 | | 57.7 | 21.14 |
| | 7.6 | Min | 31.1 | 24.44 |
| 9* | Total Package Input Power at Zero Flow ^{c, d} | | 0.0 | kW |
| 10 | Note: Y-Axis Scale, 10 | nly a visual r 0 to 35, + 5kW | 75.0 100 city (ACFM) epresentation of the data in Sect V/100acfm increments if necessary 5% over maximum capacity | ion 8 |

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program: www.

www.cagi.org


NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ROT 031

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.