

COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOI	R COMPRESSED AIR		
1	Manufacturer: Chicago Pneum	atic		
2	Model Number: CPVS 30	Date:	Aug-14	
	X Air-cooled Water-cooled	ed Type:	Screw	
	x Oil-injected Oil-free	# of Stages:	1	
3	Rated Operating Pressure	109	psig ^b	
4	Drive Motor Nominal Rating	30	hp	
5	Drive Motor Nominal Efficiency	92	percent	
6	Fan Motor Nominal Rating (if applicabl	e) NA	hp	
7	Fan Motor Nominal Efficiency	Efficiency NA		
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	28.5	Max 128.5	22.18	
	24.2	112.4	21.53	
	19.1	88.9	21.48	
	14.3	65.3	21.90	
	9.0	Min 36.0	25.00	
9*	Total Package Input Power at Zero Flow	ower at Zero Flow ^{c, d} 0.0 kW		
10	Note: Y-Axis Scale, 10 to	60.0 80.0 100.0 Capacity (ACFM) a visual representation of the data in Sec 35, + 5kW/100acfm increments if necessariale, 0 to 25% over maximum capacity		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program: www.

www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.