

## **COMPRESSOR DATA SHEET**

## **Rotary Compressor: Variable Frequency Drive**

	Model Num	hor	Chicago Pneumatic CPVS 40	Date:	Jun-14	1
		ber:	CP V 5 40	Date:	Jun-14	-
2	x Air-c	cooled	Water-cooled	Type:	Screw	-
	x Oil-in	njected	Oil-free	# of Stages:	1	
3	Rated Opera	ting Pres	sure	125	psig <sup>b</sup>	
4	Drive Motor Nominal Rating			40	hp	
5	Drive Motor Nominal Efficiency			93.5	percent	
6	Fan Motor Nominal Rating (if applicable)			1.8	hp	
7	Fan Motor Nominal Efficiency			82.1	percent	
	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>	
	36.4 Max			187.0	19.47	
	32.9			170.0	19.35	
8*	28.1			146.0	19.25	
	22.1			114.0	19.39	
	16.9			81.0	20.86	
	12.1 Min			54.0	22.41	
9*	Total Packag	ge Input l	Power at Zero Flow <sup>c, d</sup>	0.0	kW	
10	21.50 21.00 20.50 20.50 19.50 19.00 0.0 25.0 50.0 75.0 Capa			100.0 125.0 150.0 city (ACFM)	175.0 200.0	
*For mode	els that are tested	in the CA	Note: Y-Axis Scale, 10 to 35, + 5kW	5% over maximum capacity	above 35	trator
	CAGI website for a. Measure ISO 121 b. The oper c. No Load manufac d. Toleranc	a list of pa ad at the disc 7, Annex E rating presso Power. In cturer may s ce is specifie	rticipants in the third party ve charge terminal point of the com ; acfm is actual cubic feet per m ure at which the Capacity and E accordance with ISO 1217, An tate "not significant" or "0" on ed in ISO 1217, Annex E, as sho 'power" and "energy" are synon	erification program: <u>v</u> npressor package in accordar inute at inlet conditions. lectrical Consumption were nex E, if measurement of no the test report. own in table below:	www.cagi.org nce with measured for this data sheet. load power equals less than	
sed Air & Gas Institu	Volume Flow Rate at specified conditions			Volume Flow Rate	Specific Energy Consumption	No Load / Zero Power
	m	$\frac{1^3}{\min}$	<u>ft3 / min</u>	%	%	
	Bo	clow 0.5	Below 15	+/- 7	+/- 8	
		<b>.</b>				
	0.5	5 to 1.5 5 to 15	15 to 50 50 to 500	+/- 6 +/- 5	+/- 7 +/- 6	+/- 10%