

COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Chicago Pneumatic						
	Model Number: CPVS 60	Date:	Jun-14				
2	x Air-cooled Water-cooled	Type:	Screw				
	x Oil-injected Oil-free	# of Stages:	1				
3	Rated Operating Pressure	100	psig ^b				
4	Drive Motor Nominal Rating	60	hp				
5	Drive Motor Nominal Efficiency	94.1	percent				
6	Fan Motor Nominal Rating (if applicable)	1.8	hp				
7	Fan Motor Nominal Efficiency	82.1	percent				
Odh	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	53.3 Max	285.0	18.70				
	47.6	261.0	18.24				
8*	43.0	238.0	18.07				
	34.2	190.0	18.00				
	26.3	143.0	18.39				
	16.2 Min	80.0	20.25				
9*	Total Package Input Power at Zero Flow ^{c, d}	e Input Power at Zero Flow ^{c, d} 0.0					
10	Note: Graph is only a visual Note: Y-Axis Scale, 10 to 35, + 5k	20.00 19.50 19.00 18.50 17.50					

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.

- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{\min}$	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.