

## **COMPRESSOR DATA SHEET**

## **Rotary Compressor: Variable Frequency Drive**

1	MODEL DATA - FOR CO Manufacturer: Chicago Pneumatic	JWII NEOSED AIK				
	Model Number: CPVS 75	Date:	Jun-14			
2	× Air-cooled Water-cooled	Туре:				
	x Oil-injected Oil-free	# of Stages:	1			
3	Rated Operating Pressure	100	psig <sup>b</sup>			
4	Drive Motor Nominal Rating	75	hp			
5	Drive Motor Nominal Efficiency	94.5	percent			
6	Fan Motor Nominal Rating (if applicable)	3.5	hp			
7	Fan Motor Nominal Efficiency	84.5	percent			
8*	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>			
	63.1 Ma	x 350.0	18.03			
	59.4	338.0	17.57			
	53.0	305.0	17.38			
	42.7	246.0	17.36			
	32.8	184.0	17.83			
	20.2 Mi	n <b>103.0</b>	19.61			
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	0.0	kW			
10	20.00 19.50 19.00 19.00 18.50 18.00 17.50 18.00 17.50 10.00 25.0 50.0 75.0 100.0 125.0 150.0 175.0 200.0 225.0 275.0 300.0 325.0 375.0 Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35					

Consult CAGI w		ipants in the third party ver		<u>vww.cagi.org</u>			
NOTES:	a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.						
Member	b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,						
	•	e "not significant" or "0" on th					
	d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:						
	NOTE: The terms "power" and "energy" are synonymous for purposes of this document.						
Comproceed Air 9 Cae Institute	Volume Flow Rate			Specific Energy	No Load / Zero Flo		
Compressed Air & Gas Institute	at speci	at specified conditions		Consumption	Power		
	$\underline{m^3 / \min}$	<u>ft3 / min</u>	%	%			
	Below 0.5	Below 15	+/- 7	+/- 8	7		
	0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%		
	1.5 to 15	50 to 500	+/- 5	+/- 6			
T 031	Above 15	Above 500	+/- 4	+/- 5			