COMPRESSOR DATA SHEET


Rotary Compressor: Variable Displacement

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	Chicago Pneumatic						
2	Model Number:	CPVSd 20		Date:	02/15/16			
	x Air-cooled	Water-cooled		Type:	Screw			
	x Oil-injected	Oil-free		# of Stages:	1			
3	Rated Operating Pres	ssure		150	psig ^b			
4	Drive Motor Nominal Rating		20	hp				
5	Drive Motor Nominal Efficiency		91.0	percent				
6	Fan Motor Nominal Rating (if applicable)		N/A	hp				
7	Fan Motor Nominal I	Fan Motor Nominal Efficiency		N/A	percent			
8*	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	16.3 Max		65.6	24.10				
	14.1		57.0	23.90				
	12.5		51.1	23.70				
	12.4		50.7	23.70				
	5.4 Min		15.2	34.20				
9*	Total Package Input l	Power at Zero Flow ^{c, d}		0.0	kW			
10	35.00 35.00 30.00 30.00 25.00 20.00 10.00	0.0 25.050.075.0100.025.050.075.000.025.050.	ity (ACFM) presentation of /100acfm incren	f the data in Section 8 nents if necessary above 35	.675.600.625.650.0			

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:



- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

·				
Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 032

8/14 R1

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.