## **COMPRESSOR DATA SHEET**


## **Rotary Compressor: Variable Displacement**

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer:	Chicago Pneumatic					
2	Model Number:	CPVSd 20		Date:	02/15/16		
	x Air-cooled	Water-cooled		Type:	Screw		
	x Oil-injected	Oil-free		# of Stages:	1		
3	Rated Operating Pres	sure	re 175		psig <sup>b</sup>		
4	Drive Motor Nominal Rating		20	hp			
5	Drive Motor Nominal Efficiency		91.0	percent			
6	Fan Motor Nominal Rating (if applicable)		N/A	hp			
7	Fan Motor Nominal I	Fan Motor Nominal Efficiency		N/A	percent		
8*	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>			
	13.8 Max		49.2	27.20			
	13.7		48.7	27.30			
	11.5		39.2	28.30			
	10.4		33.6	29.90			
	7.0 Min		Min	18.7	36.40		
9*	Total Package Input	Power at Zero Flow <sup>c, d</sup>		0.0	kW		
10	35.00 35.00 30.00 30.00 25.00 20.00 10.00	0.0 25.050.075.0100.025.050.075.000.025.050.0	ty (ACFM) presentation of	f the data in Section 8 nents if necessary above 35	\$75.\&00.\&25.\&50.0		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:



- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

## Member

·				
Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 032

8/14 R1

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.