

## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MOI	DEL DATA	- FOR (	COMPRES	SED AIR			
1	Manufacturer:	Chica	go Pneumatio	2					
	Model Number: CPV 101VS PM					Date	: 02	2/05/25	
2	X Air-cooled Water-cooled			l		Туре	: 5	Screw	
						# of Stages	:	1	
3*	Full Load Operating Pressure <sup>b</sup>				138		psig <sup>b</sup>		
4	Drive Motor N	Drive Motor Nominal Rating			100		hp		
5	Drive Motor Nominal Efficiency				96.0		percent		
6	Fan Motor Nominal Rating (if applicable)			e)	3.0		hp		
7	Fan Motor Nominal Efficiency				89.5		percent		
8*	Input Power (kW)			Ca	pacity (acfm	) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>		
	100.3			493		20.37			
	85.4				420		20.31		
	76.6				375		20.40		
	48.8				223		21.89		
	28.6				102		27.96		
9*	Total Package	Total Package Input Power at Zero Flow c, d			0.0		kW		
10	Isentropic Effi	Isentropic Efficiency			75.6%	%			
11	Specific Power (RW/100 AC FM)	25.00 25.00 20.00 15.00 5.00 0.00	100  Note: Graph is o	nly a visual rep	300 y (ACFM) resentation of the d	ata in Section 8			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.

- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
   NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.