

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MODEL D	ATA - FOR COM	IPRESSED A	AIK	
1	Manufacture	er: Chicago Pneu	ımatic			
	Model Num	ber: CPVS 270 20	0kW		Date:	09/08/22
2	X Air-	cooled Water-	cooled		Type:	Screw
				#	of Stages:	1
3*	Full Load Operating Pressure			145	psig ^b	
4	Drive Motor Nominal Rating			268	hp	
5	Drive Motor Nominal Efficiency		!	95.0	percent	
6	Fan Motor Nominal Rating (if applicable)		icable) 11	(2x5.5)	hp	
7	Fan Motor N	Iominal Efficiency	;	89.5	percent	
8*	Input Power (kW)		Capacit	y (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	218.3			073	20.34	
	195.8			967	20.25	
	173.2			861	20.12	
	129.4			641	20.19	
	88.0			417	21.10	
9*	Total Package Input Power at Zero Flow c, d		Flow c, d	0.0	kW	
10	Isentropic E	fficiency	,	79.9	%	
11	Specific Power	35.00 30.00				
	ad _S	20.00				
		10.00				
		10.00 0 100 200	300 400 500 600	700 800 900	1000 1100	1200 1300

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- a. Measured at the discharge terminal point of the complessor package in accordance with 15O 1217, Annex E, ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data